

# SIERRA

## Residential Reverse Osmosis Systems



- ▶ Four-stage reverse osmosis drinking water system for fresh tasting, clear drinking water.
- ▶ Great tasting drinking water for pennies a gallon.
- ▶ Membrane options include 36 gpd, 50 gpd, or 75 gpd.
- ▶ Reverse osmosis membrane reduces total dissolved solids (TDS) by 96%.
- ▶ Top quality coconut carbon post-filtration provides final polishing for the freshest taste.
- ▶ Easy to install with pre-connected, color coded tubing and hygienically sealed filter cartridges.
- ▶ Easy to maintain. Replace the filter cartridges without tools.
- ▶ Compact design saves under-the-counter space.
- ▶ Manufactured in the USA.

### FOUR STAGES FOR BETTER DRINKING WATER

**Stage 1 & 2:** A combination filter, with 20 micron mesh and granular activated carbon, removes dirt and rust while reducing chlorine and organic compounds.

**Stage 3:** The reverse osmosis membrane reduces dissolved salts, metals, microorganisms and other impurities.

**Stage 4:** A coconut-based granular activated carbon postfilter is the final step in giving you fresh tasting, clear water.

### SYSTEM SPECIFICATIONS

The Sierra 4-stage reverse osmosis system delivers gallons of clean, clear drinking water. Choose from 36 gpd, 50 gpd, or 75 gpd membrane options. The Sierra features hygienically sealed filter cartridges and color-coded fittings for easy installation and service.

		NS-1N30	NS-1N50	NS-1N75
<b>Stage 1</b>	Prefilter	20 micron	20 micron	20 micron
<b>Stage 2</b>	Prefilter	GAC	GAC	GAC
<b>Stage 3</b>	RO Membrane	36 gpd	50 gpd	75 gpd
<b>Stage 4</b>	Postfilter	GAC	GAC	GAC
Dimensions		14.5"H x 12"W x 4.75"D		



### FEED WATER REQUIREMENTS

<b>Total Dissolved Solids (TDS)</b>	<2,000 mg/L (ppm)
<b>Feed Temperature</b>	40° F-100° F
<b>Feed Pressure</b>	40-80 psi
<b>Turbidity</b>	<1 NTU
<b>Silt Density Index</b>	<5
<b>pH</b>	4-8
<b>Chlorine</b>	<1.0 mg/L (ppm)

Feed water must be potable. Must be free of potential membrane foulants such as Iron, Hydrogen Sulfide and Manganese.



### REPLACEMENT PARTS

When properly maintained, the Sierra system will provide you with years of trouble-free service. The cartridges in this system must be replaced on a regular basis to maintain efficiency and to ensure high water quality. Test your water every 6 months using a digital TDS meter. Consider membrane replacement when the TDS rejection falls below 85%.

	Replacement Interval	NS-1N30	NS-1N50	NS-1N75
<b>Prefilter</b>	6-12 months	104381	104381	104381
<b>RO Membrane</b>	12 months	104583	104032	104878
<b>Postfilter</b>	6-12 months	104382	104382	104382
<b>Chrome Faucet</b>	As needed	103242		
<b>Nickel Faucet</b>		107197		
<b>2-Gallon Tank</b>		104946		
<b>Digital TDS Meter</b>		100877		